

The following samples were collected from the JFK Library, rooms/areas:

- L23
- Circulation area: M02 and lobby (LM01)
- M04 suite, rooms B, D, E, and F
- M23A
- U02, main area and room C
- U06
- U08
- Exterior samples, in front of building entrances:
 - Main library entrance – VM01
 - Back library entrance – VM02
 - Entrance to M40 – CM07

Particulate Sampling in JFK 3/28/2018

Building	RM #			Time
JFK	OIT ent: L23	Projector s: L23	Archive ent: L23	11:20-11:24
	Sa1	Sa2	Sa3	Avg
0.3	5235	5154	5075	5154.7
0.5	608	518	497	541.0
1	158	138	121	139.0
2.5	101	96	64	87.0
5	23	20	8	17.0
10	13	10	7	10.0
Temp	72.2			
RH	26.0			

Building	RM #			Time
JFK	Circ: M02B	Circ: LM01	Circ: M02A	10:56-11:00
	Sa1	Sa2	Sa3	Avg
0.3	5876	5934	3696	5168.7
0.5	951	973	698	874.0
1	254	246	276	258.7
2.5	136	155	212	167.7
5	35	30	40	35.0
10	11	17	30	19.3
Temp	72.4			
RH	26.1			

Building	RM #			Time
JFK	Office: M04B	Shelf: M04B	Entrance: M04B	10:15-10:19
	Sa1	Sa2	Sa3	Avg
0.3	3990	3826	3877	3897.7
0.5	613	587	504	568.0
1	317	242	199	252.7
2.5	264	162	143	189.7
5	84	43	35	54.0
10	59	33	40	44.0
Temp	70.9			
RH	26.8			

Building	RM #			Time
JFK	Window: M04D	Office: M04D	Entrance: M04D	10:28-10:33
	Sa1	Sa2	Sa3	Avg
0.3	3374	3621	3839	3611.3
0.5	454	706	524	561.3
1	184	411	213	269.3
2.5	130	176	164	156.7
5	35	127	42	68.0
10	38	65	37	46.7
Temp	73.0			
RH	25.6			

Building	RM #			Time
JFK	Office: M04E	Shelf: M04E	Entrance: M04E	10:34-10:38
	Sa1	Sa2	Sa3	Avg
0.3	4157	4191	4233	4193.7
0.5	486	513	485	494.7
1	156	192	154	167.3
2.5	99	124	81	101.3
5	17	22	17	18.7
10	22	22	18	20.7
Temp	73.6			
RH	25.1			

Building	RM #			Time
JFK	Shelf: M04F	Office: M04F	Entrance: M04F	10:21-10:26
	Sa1	Sa2	Sa3	Avg
0.3	3737	3851	3875	3821.0
0.5	639	568	448	551.7
1	318	238	149	235.0
2.5	296	161	102	186.3
5	66	41	19	42.0
10	56	22	19	32.3
Temp	74.1			
RH	24.8			

Building	RM #			Time
JFK	Office: M23A	Shelf: M23A	Entrance: M23A	10:40-10:45
	Sa1	Sa2	Sa3	Avg
0.3	6401	6359	5882	6214.0
0.5	554	588	606	582.7
1	1722	149	186	685.7
2.5	66	75	94	78.3
5	12	28	22	20.7
10	14	10	12	12.0
Temp	73.5			
RH	25.4			

Building	RM #			Time
JFK	Entrance: U02	Office: U02	Window: U02	11:01-11:05
	Sa1	Sa2	Sa3	Avg
0.3	5077	5416	5061	5184.7
0.5	594	603	601	599.3
1	190	153	178	173.7
2.5	95	85	57	79.0
5	11	7	12	10.0
10	13	3	5	7.0
Temp	72.7			
RH	25.9			

Building	RM #			Time
JFK	Shelf: U02C	Office: U02C	Entrance: U02C	11:07-11:11
	Sa1	Sa2	Sa3	Avg
0.3	5355	5462	5623	5480.0
0.5	587	581	605	591.0
1	153	147	156	152.0
2.5	34	54	44	44.0
5	3	8	11	7.3
10	7	1	10	6.0
Temp	73.6			
RH	25.5			

Building	RM #			Time
JFK	Hall ent: U06	Display: U06	Office ent: U06	11:12-11:16
	Sa1	Sa2	Sa3	Avg
0.3	5937	5892	6140	5989.7
0.5	611	614	654	626.3
1	149	189	175	171.0
2.5	36	54	85	58.3
5	3	2	12	5.7
10	3	7	15	8.3
Temp	72.1			
RH	26.1			

Building	RM #			Time
JFK	Table: U08	Shelf: U08	Office: U08	10:56-11:00
	Sa1	Sa2	Sa3	Avg
0.3	4834	4923	5073	4943.3
0.5	542	655	639	612.0
1	169	249	271	229.7
2.5	76	219	225	173.3
5	14	67	62	47.7
10	15	37	38	30.0
Temp	73.8			
RH	24.8			

Building	RM #			Time
JFK	Exterior: VM02	Exterior: CM07	Exterior: VM01	11:27-11:34
	Sa1	Sa2	Sa3	Avg
0.3	16836	16456	16166	16486.0
0.5	1771	721	1693	1395.0
1	715	668	640	674.3
2.5	381	306	313	333.3
5	60	36	24	40.0
10	15	19	15	16.3
Temp	57.2			
RH	40.4			